A Note on the CA25CP Cable

The CA25CP cable used to connect a UniOP CP01R-04 to an Allen Bradley SLC500 is being discontinued. This cable is **not compatible** with our new line of hardware, which includes all panels with model numbers ending in *0040*, *0041*, *0042*, and *0043*.

Panels which have our previous line of hardware, which includes all panels with model numbers ending in *0020* and *0021*, may still be connected to the SLC500 using this cable. However, we will not be manufacturing any more of these cables.

Please be advised that connecting a panel with our new line of hardware to a SLC500 using this cable will damage the PLC as well as the panel!

Technical assistance may be obtained :
In North America EXOR at 1 -513-874-4665.
In Europe EXOR Italy +39 045 - 8779068