Programming the UniOP Model MD01R-02

The UniOp model MD01R-02 is a single port, operator interface panel. This means that you must use the same port for programming the panel as well as interfacing the PLC or controller. The panel automatically sets up the port for programming when the panel is in the configuration mode. The only problem this creates is that you cannot use the standard programming cable, because the port is a 15-pin male D-sub type connector, not the standard female connector.

To program an MD01R-02, you must use the standard CA1 or CA2 with a Female to Female, 15-pin gender changer (EXOR Part # MDGEND).

The gender changer (MDGEND) will be automatically included with each CA1 or CA2 cable purchased. For customers that already have CA1 or CA2 cables, the gender changer (MDGEND) can be purchased separately.

Technical assistance may be obtained :
In North America EXOR at 1-513-874-4665.
In Europe EXOR Italy 045 - 8779068